


- LEGENDA**
- UI 9000 Btu unitate int. aferenta aparat de climatizare tip SPLIT 9000 Btu
  - UI 12000 Btu unitate int. aferenta aparat de climatizare tip SPLIT 12000 Btu
  - UE 9000 Btu unitate ext. aferenta aparat de climatizare tip SPLIT 9000 Btu
  - UE 12000 Btu unitate ext. aferenta aparat de climatizare tip SPLIT 12000 Btu
  - traseu frigorific (tevi Cu pentru lichid, gaz, cablu legatura UI-UE)
  - circuite electrice aferente instalatiei de climatizare proiectate etapa I-a
  - circuite electrice aferente retelei LAN, existente
  - circuite electrice aferente instalatiei de climatizare proiectate

**PUTERE ELECTRICA INSTALATA**  
APARAT 9000 Btu - 0,80 kW  
APARAT 12000 Btu - 1,00kW



VERIFICATOR EXPERT		NUME	SEMNATURA	CERINTA	2182/19.09.2016	REFERAT / EXPERTIZA NR. / DATA
		Beneficiar : CURTEA DE APEL ALBA IULIA			Proiect nr.: 5038/2016	
Sef proiect: ing. Nicolae DAMAN		Scara: 1:100			Faza: DTAC	
Verificat: ing. Nicolae DAMAN		Data: 08.2016			Planșă nr.: E3	
Vizat C.T.E.: ing. Ioan DAN		Descriere:			Revizia:	
Proiectat: ing. Traian ROTAR						
CAD: ing. Traian ROTAR						
Aprobat modificarea:						